

COOL ROOF RATING COUNCIL NOTIFICATION OF PRODUCT RATING

Notification Provided By: Cool Roof Rating Council 2435 N. Lombard St. Portland, OR 97217	Notification Provided To: SICC Coatings GmbH Wackenbergstr. 78-82, Berlin, Berlin 13156
--	--

Product Brand:	ClimateCoating	Product Type:	Coating
Product Model:	ThermoActive	Initial SRI:	113
Company:	SICC Coatings GmbH	3 Year SRI:	91
Contact Name:	Waldemar Walczok	Slope Types:	Low, Steep
Telephone:	+49 30 500196 30	Color:	Bright White, Multicolor



	<u>Initial</u>	<u>Weathered</u>
Solar Reflectance	0.89	0.74
Thermal Emittance	0.88	0.87
Rated Product ID	1406-0001 (smooth)	
Licensed Manufacturer	1406	
Classification	Standard Product	

Cool Roof Rating Council ratings are determined for a fixed set of conditions, and may not be appropriate for determining seasonal energy performance. The actual effect of solar reflectance and thermal emittance on building performance may vary. Manufacturer of product stipulates that these ratings were determined in accordance with the applicable Cool Roof Rating Council procedures.

The Cool Roof Rating Council (CRRC), an ISO 17065 accredited organization, has reviewed the test results data provided by a CRRC-approved ISO 17025 testing laboratory and has determined this roofing product meets the requirements described in the ANSI/CRRC S100 Standard and the CRRC-1 Program Manual. This Notification of Rating is subject to all terms and conditions of the Licensee Agreement and the documents incorporated therein by reference. This document must be reproduced in its entirety.

The Notification of Rating certificate for the approved initial ratings is valid until an updated certificate is issued by the CRRC that includes the approved three-year aged ratings. The certificate with the approved three-year aged ratings is valid until either the CRRC or Licensee removes the product from the CRRC Rated Products Directory.

			06/23/2022
Application/Technical Review Auditor	Application/Technical Reviewer	Management Approval	Certificate Date

